



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: October 23, 2016	NO.: RFI-334
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: ASI 30 Electrical clarifications

Response Required By: October 30, 2016

Drawing / Spec Reference:

Information Requested:

1. Please advise the quantity of video monitors, power requirements, and any additional electrical requirements at the video monitor wall in the lecture hall (previously addressed in RFI 331 with less detail) **See response below.**
2. Please confirm dimensions to back boxes identified with note 9 in room 135. **See response below.**
3. Please confirm dimensions to floor box in room 364.
Refer to RFI-162. - Tom Becker, Faith Group
4. T0104.B clouded room 441 but there are no changes listed. Please confirm if there is a change to room 441.
There are no changes to Room 441. - Tom Becker, Faith Group

Response:

1. Refer to PR 032 for AV System infrastructure updates. All power requirements for the video wall are supplied by the receptacles now shown at the rack in AV 160D. There will be low voltage cabling between the video display units and the AV rack. Wall penetration locations for the cables will need to be coordinated with the video display units in order to conceal the cables.
2. Although the AV junction box in 135 is shown off the wall, per keyed note 9, this junction box is intended to be wall mounted at standard receptacle height. Locate centered on wall.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark de la Fuente, WTA

Date: 11/14/16