



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: October 31, 2016	NO.: RFI-339
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Toilet accessories

Response Required By: November 07, 2016

Drawing / Spec Reference:

Information Requested:

Sheet A0210 shows details and toilet accessories legend for all bathrooms in the building. TA-05 Surface-Mounted Hand Dryer and TA-11 Small Paper Towel Dispenser are called out in the legend but not shown in the construction documents. Please confirm that this is the intent of the design.

Response:

Provide Electric Hand Dryers TA-05 in all toilet rooms. Locate Hand Dryers as indicated with keynote and junction box on the Electrical Drawings - E0101.A, E0102.A, E0103.A and E0104.A.
Attached -shows intended locations.
TA -11 is in the Lactation Room and is shown on 12/A0607.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Lynn Grossman

Date: 11.09.16

