



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: October 31, 2016	NO.: RFI-340
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Powder Actuated Fasteners

Response Required By: November 07, 2016

Drawing / Spec Reference:

Information Requested:

Spec section 092216 2.2 B.1 calls out for PAF's to be designed with a Safety Factor of 10. Paric has reached out to many different manufacturers, and they all say that the industry standard is a Safety Factor of 5. Attached is the PAF's that we plan on using on this job, however, they have a Safety Factor of 5. Please advise if the attached PAFs will be acceptable or advise of a manufacturer that meets spec requirements.

Response:

Provide Powder Actuated Fasteners (PAFs) per specification 09 2216.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Steve Ganter & Kelvin Patel (CD)

Date: 11/07/2016