



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: October 31, 2016	NO.: RFI-341
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Acoustical Plaster Ceilings

Response Required By: ~~November 07, 2016~~ **Did not receive RFI notification.**

Drawing / Spec Reference:

Information Requested:

There are two questions about the scope of work for spec section 098310. See below.

- Spec section 098310 1.4 C calls out for a 100 SF mock-up. Please confirm that this is to be an in-place mock-up in the Lecture Hall 160 that calls out for GWB-2 and Lobby C250 that calls out for APC-6 .
- ID0201 calls out the paint product for the walls in Lecture Hall 160, Lobby C250, and Commons C250B. The ceiling color for the APC-6 and GWB-2 ceilings are not specified. Please specify what color the acoustical plaster ceilings are supposed to be in these locations.

Response:

- Mockup to be only in the Lobby C250 (discuss for location & extent). Change the GWB-2 at Lecture Hall 160 to GWB-1.

- Per spec 098310, Acoustical plaster manufacturer coating color to be white to match PT-1 on adjacent GWB-1 ceiling.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 11/09/2016