



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: November 15, 2016	NO.: RFI-348
--------------------------------	--------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Follow up of RFI 292

Response Required By: November 22, 2016

Drawing / Spec Reference:

Information Requested:

Please confirm RFI292 response will not be followed and the fiber cement and window assemblies will move out relative to the face of concrete which will result in an approx. 1" overhang of the break metal relative to the curtainwall fins. The windows will not be cut down, flashing will not be reduced, and concrete will not be ground down. Please provide a detail for the transition between base of curtainwall and break metal at top of fiber cement panels.

Response:

See attached sketch.
Curtainwall contractor to provide revised detail in the final sealed copy submittal.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 11/18/2016

