



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: November 17, 2016	NO.: RFI-352
--------------------------------	--------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: Wall blocking for AV equipment

Response Required By: November 24, 2016

Drawing / Spec Reference:

Information Requested:

Please advise if any in-wall blocking is required to be installed by Paric/Guarantee Electric for AV equipment (projectors, monitors, TV's, signage, equipment racks, etc.). If so, please provide a specification for blocking and a dimensional layout.

Response:

Wall blocking is required. Refer to specification sections 061053 Rough Carpentry and 092216 Non structural metal framing for info. Coordinate av drawings and arch drawings for locations.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Lynn Grossman

Date: 11.22.2016