



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: November 17, 2016	NO.: RFI-353
--------------------------------	--------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Glazing Storefront Head Detail

Response Required By: November 24, 2016

Drawing / Spec Reference:

Information Requested:

Detail 7/A0841 currently shows a box beam with a 4" kicker supporting the head of the glazing storefront head. The framing contractor requests eliminating the box header to create a soffit condition at these locations. Please advise if that will be acceptable.

Response:

**STUD BOX HEADER REQUIRED TO SUPPORT THE OPENING.
PROVIDE ADDITIONAL CLARIFICATION REGARDING SOFFIT CONDITION.**

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 12/02/2016