



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** November 17, 2016 **NO.:** RFI-356

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Quantity of conduits on AV117

Response Required By: November 24, 2016

Drawing / Spec Reference:

Information Requested:

Av117 A note calls for (1) 1 ½" in the drawing but the conduit notes show 1 (2) 1 ½". Please advise the correct quantity.

Response:

Please provide (2) 1 1/2" conduits at WP1, WP2, WP3 and WP4 locations.

Tim Kersting - Conference Technologies

Tim Kersting

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: _____

Date: **11/18/2016**