



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** November 27, 2016 **NO.:** RFI-362

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Window Well Walls

Response Required By: December 04, 2016

Drawing / Spec Reference:

Information Requested:

1. Provide a dimension off of a column grid line in the east/west direction to locate wall
2. S0003 has the top of the inside wall at 518.10' The civil drawings C500 shows grade between wall at 550' Please advise which elevation is correct.

Response:

SEE REVISED SUBMITTAL 033000-030 UPLOADED TO DATASTART ON 12/2/16.

THE GRADE BETWEEN WALLS TO BE AT 549'-8".

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 12/09/2016