



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: November 28, 2016 **NO.:** RFI-363

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Additional details needed at green roof

Response Required By: December 05, 2016

Drawing / Spec Reference:

Information Requested:

The roofing contractor needs additional details for the north and east transitions from the Hydrotech green roofing system to the waterproofing system which runs underneath the pavers on these sides of the shaded green roof section. This can be discussed further via phonecall if needed.

Response:

THE WATERPROOFING ON THE GREEN ROOFING SYSTEM AND THE WATERPROOFING UNDERNEATH THE PAVERS SYSTEM ARE THE SAME MANUFACTURE. TRANSITION FROM ONE TO THE OTHER SHOULD BE PER MANUFACTURES STANDARD TRANSITION DETAILS. DRAINAGE BOARD FROM THE PAVER SYSTEM SHOULD BE RUN DOWN AND OVERLAP THE GREEN ROOF SYSTEM 6" - 8" MIN.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: _____

Date: **12/1/16** _____