



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: November 28, 2016	NO.: RFI-364
--------------------------------	--------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Depressions for side coiling door shop drawings

Response Required By: December 05, 2016

Drawing / Spec Reference:

Information Requested:

The side coiling doors near Stair 1 (A0501.B) required an 1 1/2" depression which was not blocked out during the slab pours. Paric would like to sawcut these depressions in per the attached shop drawings. Please advise if this is acceptable.

Response: PROVIDE MORE INFORMATION AS REQUESTED BY STRUCTURAL ENGINEER (JILL WALKER) VIA EMAIL BELOW TO DEVIN GATES ON 11/29 -
"My concern is the protection of any exposed rebar and/or headed studs. The studs are 5" and that leaves exactly 1 1/2" of cover which means the top of the heads will become exposed. The mesh can be cut out of the way, but the rebar will likely be partially buried. Can you find out from the manufacturer if the full 1 1/2" is necessary or if there is some play in that number. If we could get it down to 1" or even 1 1/4", then we could get over the existing steel pieces easier. Any steel that is left exposed will need to be epoxy coated to resist any future corrosion. Also, how will this be cut out? Will you cut part way and grind down to final elevation? Or ???"

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 12/02/2016