



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: November 28, 2016 **NO.:** RFI-365

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Roof drain elevations

Response Required By: December 05, 2016

Drawing / Spec Reference:

Information Requested:

The roof and overflow drain elevations were given for the south paver drains on A0423 but not for the roof drains on the Architectural roof plan. Please advise of the desired elevations.

Response:

ROOF DRAIN ELEVATION AT THE GREEN ROOF IS 98'-1 9/16"

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: _____

Date: **11/30/16** _____