



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: December 04, 2016	NO.: RFI-369
--------------------------------	--------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Cadaver lab cameras

Response Required By: December 11, 2016

Drawing / Spec Reference:

Information Requested:

ASI 35 does not show any cameras in the Cadaver lab (rm 191) however the AV infrastructure drawings do. Please advise which drawings take precedence.

Response:

ROOMS WITH ACCESSIBLE CEILINGS DO NOT REQUIRE CAMERA INFRASTRUCTURE (BOXES AND CONDUIT). CABLING WILL BE INSTALLED IN J-HOOKS AND POKED THROUGH THE CEILING TO THE CEILING MOUNTED CAMERA.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: _____

Date: _____