



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** December 07, 2016 **NO.:** RFI-373

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Power for access controlled doors

Response Required By: December 14, 2016

Drawing / Spec Reference:

Information Requested:

The contract documents do not show power for the access controlled doors and the door going into room 133B doesn't have any rough in in the jamb for a door position switch. Please advise what is needed as contractor is currently roughing in per plan.

Response:

Power for the access controlled doors C153, C270, C230A, and C250A are shown on the plans with keyed notes E19 and E20. Refer to upcoming ASI-044 for additional access controlled doors.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark de la Fuente, WTA

Date: 1/5/17