



**PARIC CORPORATION**  
77 Westport Plaza Suite 250  
St. Louis, MO 63146  
TEL: 636-561-9500  
FAX: 636-561-9501

---

|                                |                                |                     |
|--------------------------------|--------------------------------|---------------------|
| <b>REQUEST FOR INFORMATION</b> | <b>DATE:</b> December 12, 2016 | <b>NO.:</b> RFI-379 |
|--------------------------------|--------------------------------|---------------------|

---

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

|                                                                           |                    |
|---------------------------------------------------------------------------|--------------------|
| Project Name: 15051-Webster University Interdisciplinary Science Building | Project No.: 15051 |
|---------------------------------------------------------------------------|--------------------|

Subject: Perimeter nailer at parapet

Response Required By: December 19, 2016

Drawing / Spec Reference:

**Information Requested:**

Several details such as 1/A0453 show blocking for a perimeter nailer at the flat portion of the roof at the base of parapet. This is not needed by the roofing contractor and has been confirmed not to be required by FM Global. Please advise if this blocking can be eliminated.

**Response:**

Perimeter blocking can be eliminated.

**ARCHITECT'S RESPONSE:**

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: \_\_\_\_\_

Date: 12/14/2016