



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** December 15, 2016 **NO.:** RFI-381

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Additional lock function changes

Response Required By: December 22, 2016

Drawing / Spec Reference:

Information Requested:

Jim Ward requests the following locks be changed from classroom function to entry. Please advise this will be acceptable.

183B.2, 183C, 282.2, 282.3, 289B.1, 289B.2, 374B, 389.1, 389.3, 386.2, 386.3, 478.2, 478.3, 489.2, 489.3

Response:

[We have no objections to this change to the ND53PD Entrance Lock function for the above doors](#)

.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: [Lynn Grossman](#)

Date: [12.15.16](#)
