



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** December 16, 2016 **NO.:** RFI-384

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Storm line conflict with stair footing

Response Required By: December 23, 2016

Drawing / Spec Reference:

Information Requested:

Returned submittal 03000-29 South site wall shop drawings shows a step footing on detail E5/RSS004 with a top of ftg. elevation of 548.48'. C400 shows a 12" Storm from MH 25D to MH 12 with a flow line elevation of approximately 547'.

Suggestion: The storm line is limited due to flow restrictions. Please advise.

Response:

Block out footing in retaining wall to accommodate storm sewer.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

MINIMIZE THE WIDTH OF FOOTING STRIP TO BE BLOCKED OUT, 18" MAX. PLACE INTERRUPTED VERTICAL DOWELS FROM FOOTING TO WALL ON EACH SIDE OF THE VOIDED FOOTING. PROVIDE 1" THICK VOID FORM AROUND PIPE, UNDER WALL, TO ALLOW MOVEMENT OF RETAINING WALL. JYW/DMA

Answered By: Mark Davis
JILL WALKER / DMA

Date: December 20, 2016
12.21.2016