



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: December 20, 2016	NO.: RFI-389
--------------------------------	--------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Additional door hardware change requests

Response Required By: December 27, 2016

Drawing / Spec Reference:

Information Requested:

Jim Ward from Webster University observed that doors 276.1, 283.1, and 291.1 are storeroom locks while doors 276.2, 283.2, and 291.2 are heavy duty exit levers. Doors 383.1 and 388.1 are storeroom locks while doors 383.2 and 388.2 are classroom locks.

Jim would like to know why the doors are keyed as classroom locks and not heavy duty exit levers like the others. These should be changed to heavy duty exit levers if there is not a reason preventing them.

Response:

We understand question is about doors 383.2 and 388.2: Jim / Webster would like these doors to match 276.2/283.2/291.2 and have no lever trim on the outside.

Changing the function on these locks is Webster's option - please make the change to these to doors - match function/trim on 276.2/283.2 and 291.2 .

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Lynn Grossman

Date: 12.23.16