



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** December 27, 2016 **NO.:** RFI-390

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building

Project No.: 15051

Subject: End of Rail Confirmation

Response Required By: January 03, 2017

Drawing / Spec Reference:

Information Requested:

Please see attached sketch from La Salle Iron Works and confirm if the 8 3/4" dimension is acceptable

Response:

ALIGN FACE OF STRINGER TO FACE OF GYP.BOARD - SEE SKETCH MARKUPS.

STRINGER DIMENSION TO BE VERIFIED IN FIELD.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 01/11/2017



NO.		DATE		DESCRIPTION	
REVISIONS					
LA SALLE IRON WORKS, INC.					
SINCE 1921					
3110 LA SALLE STREET				SAINT LOUIS,	
STRUCTURE		INTERDISCIPLINARY SCIENCE BLDG.			
LOCATION		WEBSTER UNIV.			
DESCRIPTION		STAIR #2			
CUSTOMER		ATLAS IRON WORKS			
DRN. BY AB		CHK'D BY AB 7/1		CONT. 27072	
APP. SENT 7/1		APP. REC'D (A) 7/5			
APP. SENT		APP. REC'D		SHEET 9	

