



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: January 06, 2017	NO.: RFI-398
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building

Project No.: 15051

Subject: Acid neutralization tank vs sink

Response Required By: January 13, 2017

Drawing / Spec Reference:

Information Requested:

A0102.A shows a sink in rm 289A while room P0112.A shows an acid neutralization tank. Please confirm if the sink is needed.

Response:

SINK IS REQUIRED PER DRAWINGS A0102.A AND P0102.A.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 01/06/2017



