



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: January 06, 2017	NO.: RFI-400
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: OFCI PA Amplifier added in ASI-40

Response Required By: January 13, 2017

Drawing / Spec Reference:

Information Requested:

In ASI - 040 a OFCI PA Amplifier was added, no power is shown for this amp. Please advise power requirements for this amplifier and which panel the power should come from.

Response:

The PA amplifier is a POE device and will get power over ethernet. No additional power is anticipated.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark de la Fuente, WTA

Date: 1/12/17

WAP
2

CALL BOX/P.A. SPEAKER
POLE. SEE ELECTRICAL
DRAWINGS FOR POLE
INFORMATION.

22

21

7

24

4

