



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: January 06, 2017	NO.: RFI-405
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: Roof flashing clarifications

Response Required By: January 13, 2017

Drawing / Spec Reference:

Information Requested:

Please advise if the roofer is required to use a separate sheet for the wall flashings or if the field sheet can be ran up and over. If they are required to use a separate sheet is a reinforcement strip necessary or can they install plates and fasteners through the field sheet?

Response:

Details should comply with roof manufacturer's requirements for the warranty on this project. We do not require separate sheets.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: _____

Date: 01-09-2017