



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: January 06, 2017	NO.: RFI-407
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: Receptacle and cover plate color

Response Required By: January 13, 2017

Drawing / Spec Reference:

Information Requested:

All ACES lighting control devices were approved and ordered as white. Please confirm the receptacles and cover plates are to be white as well.

Response:

Per required coordination with the Architect:

Non-emergency receptacles in finished areas shall be white, with white cover plates. Emergency receptacles shall be red with red cover plates, with the word "EMERGENCY" at top.

In Conference Room 140 west wall, provide gray devices with gray cover plates (receptacles, shade controls, thermostats, data jacks, lighting controls, etc). On remaining walls of conference room, provide white devices with white cover plates.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark de la Fuente, WTA

Date: 1/24/17