



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: January 12, 2017	NO.: RFI-408
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: EAB piping tie in

Response Required By: January 19, 2017

Drawing / Spec Reference:

Information Requested:

Please see attached sketch. Paric proposes to revise the pipe routing per detail 3/M0303 to eliminate the need to get above the ceiling in EAB room 358 for tie in.

Suggestion: Please advise

Response:

Contractor proposed pipe routing is acceptable. Refer to forthcoming ASI-045 for updated pipe layouts on plans, associated heat trace, and additional information.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mike Nolte, WTA

Date: 1/23/17

