



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: January 12, 2017	NO.: RFI-409
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Level 1 corridor lighting

Response Required By: January 19, 2017

Drawing / Spec Reference:

Information Requested:

The corridor lighting RCG fixtures shown on E0201.A do not match what is shown on A0701.A. Please advise which is correct.

Response:

Sheet E0201.A is correct. However, refer to ASI-046 for lighting updates in this area.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark de la Fuente, WTA

Date: 1/16/17