



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** January 16, 2017 **NO.:** RFI-411

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Column cover at beam

Response Required By: January 23, 2017

Drawing / Spec Reference:

Information Requested:

A W21x44 beam ties into the column at A.2 and 2 line (see attached photos) which will not allow the column covers to be installed per plan. Please advise of the design intent at this location.

This occurs on Level 04.

Response:

Design Intent is to install column cover and wrap the beam per note 'C.19' on A07xx drawings.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 01/18/2017



Approx. 74"
A.F.F.

Approx. 53"
A.F.F.



