



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: January 16, 2017	NO.: RFI-412
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: Continuous wire at masonry veneer

Response Required By: January 23, 2017

Drawing / Spec Reference:

Information Requested:

042000-021 came back with the box for continuous wire finish selected. Per spec 042000 2.5A this is only required if the back of face brick to the face of stud wall exceeds 4 1/2". Per wall assemblies WA-B1 and WA-B2 on sheet A0400 this dimension is 4 1/8" and the continuous wire is not shown in these details. Please confirm the continuous wire is not needed.

Per deletion of 2.5c spec section 04200 continuous wire is not required.

Response:

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: _____

Date: **1/19/17** _____