



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: January 17, 2017	NO.: RFI-415
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Bollards and actuator electrical requirements

Response Required By: January 24, 2017

Drawing / Spec Reference:

Information Requested:

In the Exterior Aluminum Hardware submittal 087100.01-001 bollards and actuators were requested for door XC270A.2 (or X202.2 per RFI283). The electrical requirements were not addressed for this door in ASI#44 as anticipated and there appears to be no power provisions for this opening per sheet E102.A. Please advise what electrical requirements are necessary at this opening.

Response:

Per Webster University, no automatic door opener required for this door. Hence no electrical requirements for this door.
Door hardware requirements will be updated in the revised submittal review.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 01/23/2017