



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: January 23, 2017	NO.: RFI-422
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.:	15051
---------------	---	--------------	-------

Subject: Exterior lighting at southeast stairs

Response Required By: January 30, 2017

Drawing / Spec Reference:

Information Requested:

E0001 shows EH lights to be installed in the masonry at the southeast stairs. This masonry is scheduled to start 1/30. Please provide a layout for the lights so that correct blockouts can be installed.

Response:

Locate step lights approximately 24" above stair profile and 4' O.C. Coordinate exact fixture location relative to bricks with architect.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark de la Fuente, WTA

Date: 1/25/17

L16

1EH1-2

eh



(8)EH,2,eh

EG3,2,ea

