



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** January 26, 2017 **NO.:** RFI-428

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Decorative handrail at lecture hall

Response Required By: February 02, 2017

Drawing / Spec Reference:

Information Requested:

Per discussions with Atlas and Cannon on 1/10/17 please see attached understanding of what lecture hall rails should look like (in elevation).

Please advise if the current sketch, which shows the center posts aligned with the mullions and the top and bottom posts 1' minimum beyond the extents of the ramp reflect the design intent.

Please advise if the loads and materials are acceptable per DMA.

Response:

Attachment missing.

Note, the railings are delegated-design and all the performance requirements need to be attested per specifications.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

- 1.3 ACTION SUBMITTALS
- A. Product Data: For the following:
 - 1. Manufacturer's product lines of mechanically connected railings.
 - 2. Railing brackets.
 - 3. Grout, anchoring cement, and paint products.
 - B. LEED Submittals:
 - 1. Product Data for Credit MR 4: For products having recycled content, documentation indicating percentages by weight of postconsumer and preconsumer recycled content. Include statement indicating cost for each product having recycled content.
 - C. Shop Drawings: Include plans, elevations, sections, details, and attachments to other work.
 - D. Delegated-Design Submittal: For railings, including analysis data signed and sealed by the qualified professional engineer responsible for their preparation.

Answered By: Kelvin Patel

Date: 01/26/2017