



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: January 26, 2017 NO.: RFI-429

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Elevator Control Room 176 Fire Damper

Response Required By: February 02, 2017

Drawing / Spec Reference:

Information Requested:

Are fire dampers required in elevator control room 176 for the transfer grill and VF2 ductwork penetration on drawing M0101.A? On drawing G0202 a 2 hour fire rating is depicted around elevator control room 176,

Response:

Fire dampers are required for duct penetrations of rated walls at Elevator Control Room #176.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: **Mike Nolte, WTA**

Date: **2/10/17**