



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** January 30, 2017 **NO.:** RFI-430

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Thermostat Locations Needed

Response Required By: February 06, 2017

Drawing / Spec Reference:

Information Requested:

Thermostat locations are not shown for the following VAV's and CUHs. Please provide locations for each of these terminal Units:

CUH 101, VAV 119, CUH 102, VAV 202, VAV 203, VAV216, CUH 203, CUH 204, VAV 208, CUH 201, CUH 202, VAV 322.

Response: For CUH-102: CUH-102 is to be installed on 1st level with thermostat installed on 2nd level. Provide wall mounted thermostat per 230500-2.14-D in location to be shown on forthcoming ASI-050.
For CUH-201: Note that submitted unit is larger than basis of design unit. Contractor shall coordinate installation of cabinet unit in ceiling with Electrical Contractor for light location. Provide with factory-mounted and wired thermostat and speed control switch per specification 235000-2.14-B-7.
For CUH's-101, 202, 203, & 204: Provide wall mounted thermostat per 230500-2.14-D in location to be shown on forthcoming ASI-050.
For VAV's-119, 202, 203, 208, 216, 322: Refer to forthcoming ASI-050 for thermostat locations.
Contractor is responsible to provide and install guards on thermostats as required by specification 239500-3.2-E for thermostats in entrances (vestibules), public areas, etc.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mike Nolte, WTA

Date: 2/15/17