



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: February 02, 2017 NO.: RFI-436

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Finish on F-2 Expansion Joint Cover

Response Required By: February 09, 2017

Drawing / Spec Reference:

Information Requested:

The F-2 expansion joint approved in 079500-003 is only allowed in a milled aluminum finish from the supplier. The specs state "custom color as selected by Architect from manufacturers full range". During the architectural sheet metal pre-install meeting it was discussed that the cover should match the metal panels. Please advise if the material is to be painted to match.

Response:

Per discussion with Matt Horton of Paric, provide Fluoropolymer coating to match EAB roof trim.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 02/15/2017