



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: February 07, 2017	NO.: RFI-437
--------------------------------	--------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Knox box requirements

Response Required By: February 14, 2017

Drawing / Spec Reference:

Information Requested:

Please advise if the knox box is OFOI or CFCI and provide a spec if CFCI.

Response:

Knox box is a CFCI item.
Please select a knox box approved by Fire department & Webster University.
Refer to knoxbox.com for more information.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 02/15/2017