



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: February 07, 2017	NO.: RFI-438
--------------------------------	--------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Under cabinet lights in rm 200A and 300A

Response Required By: February 14, 2017

Drawing / Spec Reference:

Information Requested:

In rooms 200A and 300A there is 7'11" of cabinets on the east wall and the electrical dwgs, E0202A and E0203A, shows 2 - 4' fixtures under the cabinets. Please advise if this is to be one 4' fixture or if another sized fixture should be used.

Response:

Provide one 4' fixture centered between the cabinets and eliminate the other fixture.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark de la Fuente, WTA

Date: 2/15/17