



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: February 13, 2017 **NO.:** RFI-444

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Drain tile location at courtyard stair walls

Response Required By: February 20, 2017

Drawing / Spec Reference:

Information Requested:

Detail 2/A507.A indicates the drain tile to be on the inboard side of the shorter stair wall thereby putting it underneath the concrete stair treads. C400 shows the drain tile to be on the outboard side. Please confirm which location is to be followed. For reference - Detail 2/A508.B and C400 show the drain tile underneath the concrete stair treads on the North courtyard stair wall.

Response:

C400 is incorrect, the drain tile should be as shown on Detail 2/A507.A.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark Davis

Date: 2-27-2017