



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** February 13, 2017 **NO.:** RFI-446

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Feature Wall Paneling Joints

Response Required By: February 20, 2017

Drawing / Spec Reference:

Information Requested:

EG Drawings call out for panels on Feature Wall to be ¾" Painted MDF with 3/32" Butt Joint Reveal. Due to the size of these panels and this wall, the panel supplier is worried about any shrinkage or movement due to moisture over the life-cycle of the building. The supplier advised that the Feature Wall should be a painted finished wall behind the panels in case any of the panels have slight movement. Please advise if the wall behind the Feature Wall Panels will be a finished wall and that the owner understands that they may be some movement of the panels due to the size of the wall.

Response:

Provide painted, finished wall behind the paneling as recommended. Color to be Benjamin Moore - BM OC-9 Ballet White

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Lynn Grossman

Date: 02.16.17