



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: February 20, 2017	NO.: RFI-450
--------------------------------	--------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: Expansion and deflection distances between EAB and ISB

Response Required By: February 27, 2017

Drawing / Spec Reference:

Information Requested:

To correctly size the expansion joints in the mechanical piping between the buildings the contractor needs to know the expansion and deflection distances between the two.

Please advise.

Response:

The flex connection in the piping should accommodate the 6" expansion joint between the buildings. This is based on amplified displacements calculated from strength level seismic forces. Maximum vertical deflection due to gravity loads is 1".

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: JILL WALKER / DMA

Date: 02.21.2017