



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** February 22, 2017 **NO.:** RFI-455

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: switch location at coiling door

Response Required By: March 01, 2017

Drawing / Spec Reference:

Information Requested:

The coiling fire door has a switch to manually operate. Please advise of the desired location. The manufacturer recommends the location be where the door can be observed while operating.

Response:

Provide more information on switch - size, locations (can it be 18" AFF or standard height or any accessible height), back box, is it keyed, finishes, picture.

Limitations - distance from the door.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 03/01/2017