



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: February 22, 2017 **NO.:** RFI-457

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Fire Rating of Toilet Partition

Response Required By: March 01, 2017

Drawing / Spec Reference:

Information Requested:

Class A Fire-Rated Partitions are not available from any of the 3 specified manufacturers in spec section 102113.19. Class B is available from these manufacturers. Please confirm that Class B is acceptable. If not, please advise on a manufacturer who offers Class A partitions.

Response:

Class B is acceptable, it meets code requirements.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 02/24/2017