



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: February 27, 2017	NO.: RFI-463
--------------------------------	--------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: RFI 318 Green Roof light weight aggregate

Response Required By: March 06, 2017

Drawing / Spec Reference:

Information Requested:

Please advise if the light weight aggregate in the GR 50 portion is required for the Webster ISB project. Aggregate was not specified in 071413 Section I or indicated on RA-T2 on A400 therefore it was not included in the GMP. If it is required, please advise of a specification and source of this material.

Response:

It is the design team's understanding that this lightweight aggregate is a required component of the American Hydrotech Garden Roof Assembly which is the product assembly the contractor selected to fulfill the requirements of the green roof assembly in specification section 329500.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Zach Snovelle

Date: 03/01/2017