



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** March 15, 2017 **NO.:** RFI-484

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Stainless steel courtyard stair rail shop drawing collars

Response Required By: March 22, 2017

Drawing / Spec Reference:

Information Requested:

Page 3/7 (by steel fabricator) on 055213-007 states "collar detail similar to vertical posts of railing with lights", page 6/7 (by lighting contractor) states "same collar detail on vertical posts of railing without lights".

The collar on the lighting contractor's drawing is just a typical detail by the drafter and not detailed further. Please confirm if a collar is required and if so which details should be used.

Response:

NO COLLAR REQUIRED FOR RAILS ON BOTH SIDES.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 03/17/2017