



**PARIC CORPORATION**  
77 Westport Plaza Suite 250  
St. Louis, MO 63146  
TEL: 636-561-9500  
FAX: 636-561-9501

---

**REQUEST FOR INFORMATION      DATE: March 15, 2017      NO.: RFI-487**

---

To: Cannon Design

---

Attn: Kelvin Patel

---

From: Paric Corporation

---

Requested By: Joe Voypick

---

Project Name: 15051-Webster University Interdisciplinary Science Building      Project No.: 15051

---

Subject: Laboratory Casework installation fasteners

---

Response Required By: March 22, 2017

---

Drawing / Spec Reference:

---

**Information Requested:**

Please advise if zinc coated fasteners can be utilized for laboratory casework installation. Specification section 3.1 does not require the use of stainless. Stainless fasteners will be utilized for the Gas Cylinder cabinet as required in specification section 2.9.

**Response:**

**STAINLESS STEEL FASTENERS REQUIRED. PROVIDE PRICING TO EVALUATE.**

**ARCHITECT'S RESPONSE:**

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By:                     Kelvin Patel                    

Date:                     03/23/2017