



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: March 20, 2017	NO.: RFI-489
--------------------------------	-----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: Ladder rung clarifications

Response Required By: March 27, 2017

Drawing / Spec Reference:

Information Requested:

Per 21/A0551 the rungs of the elevator pit are to have an abrasive coating. The steel contractor has used both non-slip paint with grit and non-slip tape in the past with issues of peeling.

Suggestion: Contractor recommends to use rebar as non-slip rungs. Please provide desired material if not acceptable.

Response:

CONTRACTOR SUGGESTION IS ACCEPTABLE, PROVIDED THE LADDER MEETS CODE REQUIREMENTS PER SPECIFICATIONS 055000, 2.11.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 03/23/2017