



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** March 20, 2017 **NO.:** RFI-492

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science
Building

Project No.: 15051

Subject: Vestibule door heights clarifications

Response Required By: March 27, 2017

Drawing / Spec Reference:

Information Requested:

XC250 is shown to be 7' tall and C250A is shown to be 7' 10 ½" tall. Please confirm this is the design intent.

Response:

REVISE THE HEIGHT OF DOOR C250A TO BE 7'-0", SIMILAR TO XC250.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 03/22/2017