



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: March 27, 2017	NO.: RFI-493
--------------------------------	-----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: Fume hood motion sensors

Response Required By: April 03, 2017

Drawing / Spec Reference:

Information Requested:

Please confirm that motion sensors are not required for operator presence due to the fume hoods being "low flow". (~60FPM Face Velocity)

Motion sensors cannot be used with face velocity this low.

Response:

Zone Presence Sensors are not required due to the low flow design of the submitted JMP hood. The submitted hood is rated for use at approximately 60 fpm which already saves energy over the standard hood design of 100 fpm.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mike Nolte, WTA

Date: 4/10/17