



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: March 29, 2017 NO.: RFI-499

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: 120V power for lights and receptacles on AHU#3 and AHU#4

Response Required By: April 05, 2017

Drawing / Spec Reference:

Information Requested:

The BNL1 panel schedule shows power for AHU#1 and AHU#2 but not for 3 or 4. Please advise

Response:

Per Owner direction, do not add a dedicated circuit for AHU-3/4 lights at this time. If the Owner determines these lights are critical for proper maintenance, a circuit will be added in the future.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: **Mark de la Fuente, WTA**

Date: **4/11/17**