



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: March 29, 2017	NO.: RFI-500
--------------------------------	-----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.:	15051
---------------	---	--------------	-------

Subject: Restroom Wall tile Elevations

Response Required By: April 05, 2017

Drawing / Spec Reference:

Information Requested:

The finish schedule calls for tile and paint at the restroom walls but no elevation to transition is given. Please advise

Response:

Refer to Interiors, ID Series sheets:
Finish Schedule note 14 indicates that ceramic tile should be full height where it occurs.
Finish Transition plans ID0101 - ID0104 Indicate which walls are CT and which are Paint.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Lynn Grossman

Date: 03.31.17