



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: March 30, 2017	NO.: RFI-504
--------------------------------	-----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Pavers at C270a.1 entrance

Response Required By: April 06, 2017

Drawing / Spec Reference:

Information Requested:

A0102.B shows precast pavers being placed all the way to the face of the existing structure at the EAB connector, however there is no sub-base specified at this location (see sketch). Paric proposes to pour a concrete pad under the pavers.

Suggestion: Please advise

Response:

NOTE, PER L400 THE PAVERS EXTEND TO THE CURTAINWALL.

REFER DETAILS 'G' AND 'F' ON SHEET 'L501'.

Answered By: Kelvin Patel

Date: 04/12/2017



