



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: April 05, 2017	NO.: RFI-507
--------------------------------	-----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Proposed "breaks" in stair 1 BA light fixture

Response Required By: April 12, 2017

Drawing / Spec Reference:

Information Requested:

Due to the complexity of stair 1 and the tolerances required, the lighting contractor is proposing to separate the BA type fixture into two separate fixtures at the 2nd and 3rd floor landings. See attached sketch. Contractor proposes to remove the angle circled and leave a 5" to 6" gap prior to starting the second run under the stairs.

Response: In order for the lights to fit correctly within the stairwell, accurate field dimensions will be required. We understand that due to the remaining project schedule and the light fixture lead times, it may not be possible to wait for the stairs to be fully built prior to ordering the light fixtures. In-lieu of breaking the visual continuity of the light fixtures, we propose a "keystone" approach to the lighting system. Specific light fixture segments could be delayed while the stairwells are built, allowing the bulk of the stairwell lighting product to be ordered and installed. Then once the stairwells are built and actual field measurements are available, the final pieces can be ordered and installed.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark de la Fuente, WTA

Date: 4/11/17

Remove this
Angle and leave
a 5" gap between
the run of fixture
under the stairs
and the 90 degree
angle

